

Test Report No. AJHL1701000321FB Date: JAN.24, 2017 Page 1 of 4

CCGRASS

FLOOR 19, DADI BUILDING, NO. 56, HUAQIAO ROAD, NANJING

The following sample(s) was / were submitted and identified on behalf of the client as:

Sample Description: ARTIFICIAL GRASS

SGS Ref No.: NJIN1701000091ML

<u>Product Specification</u>: HOLY PX2, SOFT FS PX2, NOBEL PX2, FINE DUO PX2, PRESTIGE PX2, METIS PX2, MUSE PX2, SOFT AS PX2, ATURFPRO PX2, LIBRA PX2, LIBRAPRO PX2, VISTA PX2,

OMEGA PX2, MAXPRO PX2, WAYUP PX2, MEMORY PX2, M BLADE PX2, SOFT MS PX2,

CRYSTALPRO PX2, MAX, ULTRASPORT

Manufacturer: CCGRASS
Material and Mark: PE&PP

Test Requested:

EN 13501-1:2007+A1:2009 Fire classification of construction products and building elements—Part 1: Classification using data from reaction to fire tests, Class E_{fl}

Test Results: -- See attached sheet -

Test Period:

Sample Receiving Date : JAN.10, 2017

Test Performing Date : JAN.10, 2017 TO JAN.23, 2017

Signed for and on behalf of SGS-CSTC Co., Ltd. Anji Branch

Allen Zou

Technical Manager





Test Report

No. AJHL1701000321FB

Date: JAN.24, 2017

Page 2 of 4

I. Test conducted

This test was conducted as per EN 13501-1:2007+A1:2009 Fire classification of construction products and building elements — Part 1: Classification using data from reaction to fire tests. And the test methods as following:

EN ISO 11925-2:2010 Reaction to fire tests — Ignitability of building products subjected to direct impingement of flame — Part 2: Single-flame source test.

II. Details of classified product

Description	ARTIFICIAL GRASS	
Color	Green	

III. Test results

Test method	Parameter	Number of tests	Results
EN ISO 11925-2 Exposure = 15 s		6	YES

IV. Classification and direct field of application

This classification has been carried out in accordance with EN 13501-1:2007+A1:2009.

a) Classification

The product, ARTIFICIAL GRASS, classification is as following,

Fire behaviour	
E _{fl}	

Reaction to fire classification: E_{fl}

Remark: The classes with their corresponding fire performance are given in annex A.

Statement: The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test; they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use.

Warning:

This classification report does not represent type approval or certification of the product.

The test laboratory has, therefore, play no part in sampling the product for the test, although it holds appropriate references to the manufacturer's factory production control that is aimed to be relevant to the samples tested and that will provide for their traceability.

To be continued...



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents at http://www.sgs.com/en/Terms-e-Document.sgs.com/en/Terms-en/Terms-e-Document.sgs.com/en/Terms-en/Terms-e-Document.sgs.com/en/Terms-e-Document.sgs.com/en/Terms-en/Terms-e-Document.sgs.com/en/Terms-e-Document.sgs.com/en/Terms-e-Document.sgs.com/en/Terms-e-Document.sgs.com/en/Terms-e-Document.sgs.com/en/Terms-e-Document.sgs.com/en/Terms-e-Document.sgs.com/en/Terms-e-Document.sgs.com/en/Terms-e-Document.sgs.com/en/Terms-e-Document.sgs.com/en/Terms-e-Document.sgs.com/en/Terms-e-Document.sgs.com/en/Terms-e-Document.sgs.com/en/Terms-e-Document.sgs.com/en/Terms-e-Document.sgs.com/en/Terms-e-Document.sgs.com/en/Terms-e-Document.sgs.com/en/Terms-e-Document.sgs.com/en/Terms



Test Report

No. AJHL1701000321FB

Date: JAN.24, 2017

Page 3 of 4

Annex A

Classes of reaction to fire performance for floorings

class	Test metho	ods	Classification		Additional classification	
A1 _{fl}	EN ISO 1182ª	and	∠T≤30°C, ∠m≤50%, t _f =0(i.e. no sustained flamin	and and	-	
	EN ISO 1716		PCS≤2.0MJ/kg ^a PCS≤2.0MJ/kg ^b PCS≤1.4MJ/m ^{2 c} PCS≤2.0MJ/kg ^d	and and and	-	
A2 _{fl}	EN ISO 1182 ^a or		∆T≤50℃,	and and	-	
	EN ISO 1716	and	PCS≤3.0MJ/kg ^a PCS≤4.0MJ/m ^{2 b} PCS≤4.0MJ/m ^{2 c} PCS≤3.0MJ/kg ^d	and and and	-	
	EN ISO 9239-1 °		Critical flux ^f ≥8.0kW/ m ²		Smoke production ^g	
B _{fl}	EN ISO 9239-1 ^e	and	Critical flux f ≥8.0kW/ m2		Smoke production ⁹	
	EN ISO 11925-2 h Exposure =15s		Fs≤150mm within 20 s		-	
C _{fl}	EN ISO 9239-1 ^e	and	Critical flux ^f ≥4.5kW/ m ²		Smoke production ^g	
	EN ISO 11925-2 h Exposure =15s		Fs≤150mm within 20 s		-	
D _{fl}	EN ISO 9239-1 e	and	Critical flux f ≥3.0kW/ m2		Smoke production ⁹	
	EN ISO 11925-2 h Exposure =15s		Fs≤150mm within 20 s		-	
E _{fl}	EN ISO 11925-2 h Exposure =15s		Fs≤150mm within 20 s		-	
F _{fl}	No performance determined					

To be continued...



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx.and, for electronic format documents, and the first of the conditions of the condi

No. 301, Sunlight Road, 2 Block, Sunlight Industry Zone, Anji County, Zhejiang Province, China 313300 t (86-572) 5018825 f (86-572) 5018829 www.sgsgroup.com.cn 中国·浙江·安吉县阳光工业园二区阳光大道301号 邮编:313300 t (86-572) 5018825 f (86-572) 5018829 e sgs.china@sgs.com

^a For homogeneous products and substantial components of non-homogeneous products.

^b For any external non-substantial component of non-homogeneous products.

^c For any internal non-substantial component of non-homogeneous products.

^d For the product as a whole.

^e Test duration = 30 min.

^f Critical flux is defined as the radiant flux at which the flame extinguishes or the radiant flux after a test period of 30 min, whichever is the lower (i.e. the flux corresponding with the furthest extent of spread of flame).

^g **s1** = Smoke ≤ 750 % minutes;

s2 = not s1.

^h Under conditions of surface flame attack and, if appropriate to the end use application of the product, edge flame attack.



Test Report

No. AJHL1701000321FB

Date: JAN.24, 2017

Page 4 of 4

Photo Appendix:



SGS authenticate the photo on original report only

End of Report



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx. Attention is drawn to the limitation of liability, indeminification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sold responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company, Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) are retained for 30 days only.

**Attention:To check the authenticity of testing / inspection report & certificate, please contact us at telephone:(86-755) 8307